WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67480
Permit No.
Basin 091

NOTICE OF INTENT No. 31448

1. OWNER Hal Tengberg
MAILING ADDRESS 1894 Highway 50 E. #4347
Carson City, NV 89701

ADDRESS AT WELL LOCATION
1220 Buffalo Road
Reno, NV

2. LOCATION SW ¼ SE ¼ Sec. 35 T. 24 N/S R. 18 E Washoe County
PERMIT NO. ~~43164~~ No Permit this Loc. Issued by Water Resources | Parcel No. 078-262-25 | Sierra Ranchos Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| top soil | | 0 | 3 | 3 |
| clay & course sand | | 3 | 153 | 150 |
| clay | | 153 | 170 | 17 |
| course sand | | 170 | 180 | 10 |
| clay | | 180 | 185 | 4 |

Date started April 7, 1997
Date completed April 8, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| Approx | 20 | 170 | 2 |

8. WELL CONSTRUCTION
Depth Drilled 185 Feet Depth Cased 185 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 9 7/8 Inches | | 0 Feet | 185 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | 13 | 0.188 | +1 | 185 |

Perforations:
Type perforation mill slot
Size perforation 1/8 x 4"
From 144' feet to 184 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 54'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 54 feet to 184 feet

9. WATER LEVEL
Static water level 0 feet below land surface
Artesian flow 15 G.P.M. 3 P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Miller & Sons Drilling (Contractor)
Address P.O. Box 8056 (Contractor)
Reno, NV 89507

Nevada contractor's license number issued by the State Contractor's Board 37915

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2067

Signed Wayne Miller
By driller performing actual drilling on site or contractor

Date 6/27/97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627