

OFFICE USE ONLY
 Log No. 6752
 Permit No. 049
 Basin

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30684

1. OWNER FARLY Hicks ADDRESS AT WELL LOCATION RIO Drive
 MAILING ADDRESS 610 CHRIS AVE, ELKO, NV 89501

2. LOCATION SE 1/4 NE 1/4 Sec 1 T. 34 N/S R. 54 E. ELKO County
 PERMIT NO. 05-510-153 Adobe Heights Subdivision Name

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Loam mix with Rock		0	25	25
Cemented Gravel		25	60	35
Clay Concrement		60	90	30
SOFT SAND STONE		90	112	22
Brown sand stone		112	120	8
Red sand stone		120	232	112
SAND & Gravel	K	232	240	8
CLAY		240	252	12
Concrement		252	360	108
Black SAND		360	380	20
Broken Red Rock	A	380	420	40

8. WELL CONSTRUCTION
 Depth Drilled 420 Feet Depth Cased 420 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 420 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.92</u>	<u>1.88</u>	<u>12</u>	<u>420</u>

Perforations:
 Type perforation slots
 Size perforation 3/16 x 3"
 From 380 feet to 420 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 54

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 54 feet to 420 feet

9. WATER LEVEL
 Static water level 220 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

Date started 11-20-95 JULY 12, 1996
 Date completed JULY 18, 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Apoka</u>	<u>35</u>		<u>45</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name FERTIG Drilling Co Contractor
 Address P.O. Box 525 ELKO NV 89503 Contractor

Nevada contractor's license number issued by the State Contractor's Board 31904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584-T1

Signed [Signature]
 _____ Driller performing actual drilling on site or contractor

Date _____