WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67531
Permit No.
Basin 0417

NOTICE OF INTENT NO. 32041

1. OWNER Flores, Saturnino & Gloria
MAILING ADDRESS 66 Garcia Ln
Elko, NV 89801
ADDRESS AT WELL LOCATION None

2. LOCATION NE ¼ SE ¼ Sec. 12 T. 34 N S R. 66 E. Elko County
PERMIT NO. (Issued by Water Resources) Lot 28, Blk B (Parcel No.) Last Chance Ranch Unit #3 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	1	1
Clay (tuff)		1	110	109
Broken lava rocks	1gpm	110	115	5
Tuff		115	152	37
Tuff with rhyolite fragments	6gpm	152	167	15
Tuff		167	198	31
Broken Rhyolite	12gpm	198	219	21
Tuff		219	225	6
T.D. 225				

RECEIVED 96 SEP 23 AM 11:13 STATE ENGINEER'S OFFICE

Date started 8-14, 1996
Date completed 8-24, 1996

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12½	From Bottom	½

8. WELL CONSTRUCTION
Depth Drilled 225 Feet Depth Cased 226½ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 Inches		50 Feet	225 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1½	225

Perforations:
Type perforation Mill slots
Size perforation ⅛ x 3
From feet to feet
From 98 feet to 118 feet
From 150 feet to 220 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 40
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 40 feet to T.D feet

9. WATER LEVEL
Static water level 98 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Muth Drilling Co. (Contractor)
Address 203 Pine St. (Contractor)
Elko, NV 89801
Nevada contractor's license number issued by the State Contractor's Board 10819
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
Signed James Y. Muth (By driller performing actual drilling on site or contractor)
Date 9-14-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627