WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67535
Permit No.
Basin 93A

NOTICE OF INTENT NO. 32807

1. OWNER Michael Sheely
MAILING ADDRESS 20 Jacana ct.
Reno nv.

ADDRESS AT WELL LOCATION
1330 Antelope Valley rd.
Reno, NV.

2. LOCATION SW ¼ NE ¼ Sec. 27 T. 22 N/S R. 19 E. Washoe County
PERMIT NO. n/a (Issued by Water Resources) | 79-450-32 (Parcel No.) | Antelope Valley (Subdivision Name) Rock Est. #181 Part 2 of Part 4

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
decomposed shist		0	40	
fractured schist		40	420	
5 gpm	325			
25 gpm	400			

Date started 3-13, 19 96
Date completed 5-11, 19 96

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
aprox.	30	420	2

8. WELL CONSTRUCTION
Depth Drilled 420 Feet Depth Cased 420 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches		0 Feet	40 Feet
9 7/8 Inches		40 Feet	240 Feet
8 1/2 Inches		240 Feet	420 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	14	.188	-1	420

Perforations:
Type perforation mill slot
Size perforation 1/8x3"
From 320 feet to 420 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 60' feet to 420 feet

9. WATER LEVEL
Static water level 304 feet below land surface
Artesian flow none G.P.M. none P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Miller & Sons Drilling (Contractor)
Address 605 Spice Island dr. Sparks 89431 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 37915
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
Signed (By driller performing actual drilling on site or contractor)
Date 6-24-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627