


Log No. 67537

Permit No. _____

Basin _____



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32037

1. OWNER UMBALDO GONZALEZ ADDRESS AT WELL LOCATION None
 MAILING ADDRESS 114 Park Rd. Elko, NV 89801

2. LOCATION SW 1/4 SW 1/4 Sec. 12 T. 34. N. 55 E. ELKO, NV County _____
 PERMIT NO. _____
 Issued by Water Resources 67537, ELKA Parcel No. _____
LAST CHANCE RANCH, Unit #3 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Tuff		0	75	75
Fossil soil		75	80	5
Sandstone - soft black	✓	80	98	18
Siltstone - brown	✓	98	128	30
Claystone		128	132	
T.D. 132				

8. WELL CONSTRUCTION
 Depth Drilled 132 Feet Depth Cased 135 1/2 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
1.0 Inches 0 Feet 5.0 Feet
8 Inches 50 Feet 132 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.92</u>	<u>.158</u>	<u>1 1/2</u>	<u>132</u>

Perforations:
 Type perforation Mill. slots
 Size perforation 1/8 x 3
 From _____ feet to _____ feet
 From 70 feet to 135 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 52 _____
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 52 feet to 132 feet

9. WATER LEVEL
 Static water level 7.0 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Muth Drilling Co.
 Contractor
 Address 203 Pine Street
Elko, NV 89801

Nevada contractor's license number issued by the State Contractor's Board 10819
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
 Signed James V. Muth
 By driller performing actual drilling on site or contractor
 Date 7-26-96

Date started 7-15, 1996
 Date completed 7-24, 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
70	110	
40	110	
<u>40</u>	<u>55</u>	<u>30 min</u>
<u>12</u>	<u>From bottom</u>	<u>1/2 hr.</u>
<u>40</u>	<u>110</u>	<u>20 min</u>
<u>12</u>	<u>110</u>	<u>1 hr.</u>