


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 67542
 Permit No. _____
 Basin. 103



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53648

1. OWNER Pete Howe ADDRESS AT WELL LOCATION 244 S. 2nd Dayton NV
 MAILING ADDRESS PO Box 1580 Dayton NV 89403
 2. LOCATION NW 1/4 SW 1/4 Sec 19 T. 15N N/S R. 22 E County _____
 PERMIT NO. 16-352-08 Parcel No. _____ Subdivision Name Dayton Ranch est
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SAND</u>		<u>0</u>	<u>20</u>	<u>20'</u>
<u>SAND + GRAVEL</u>		<u>20</u>	<u>200</u>	<u>180'</u>
<u>clay</u>		<u>200</u>	<u>220</u>	<u>20'</u>

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 220
9 5/8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>.188</u>	<u>71</u>	<u>220</u>

Perforations:
 Type perforation factory part
 Size perforation 3/32
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From 180 feet to 220 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Plured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 220 feet

Date started 7-10 1997
 Date completed 7-11 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
	<u>207</u>	<u>N/A</u>	<u>2 Hrs</u>

9. WATER LEVEL
 Static water level: 80 feet below land surface
 Artesian flow NA G.P.M. NA P.S.I.
 Water temperature 60 °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Blain Drilling Contractor
 Address PO Box 1255 Contractor
CC NV 89702
 Nevada contractor's license number issued by the State Contractor's Board: 10950
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1878
 Signed W. E. Eula
 By driller performing actual drilling on site or contractor
 Date 7-15-97

RECEIVED
 37 SEP - 3 AM 11:34
 STATE ENGINEERING OFFICE