

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 356024

1. OWNER Skywest development ADDRESS AT WELL LOCATION 9330 Via Camino SS, NV
 MAILING ADDRESS Pen

2. LOCATION SE 1/4 NE 1/4 Sec. 25 T. 17 N/S R. 24 E Pen County Pen
 PERMIT NO. 17-535-11 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other 102

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|----------------------|--------------|------------|------------|------------|
| <u>Sand</u> | | <u>0</u> | <u>2</u> | <u>2</u> |
| <u>Sand Gravel</u> | | <u>2</u> | <u>21</u> | <u>19</u> |
| <u>Sand Gravel</u> | | <u>21</u> | <u>110</u> | <u>89</u> |
| <u>Sand Gravel</u> | | <u>110</u> | <u>121</u> | <u>11</u> |
| <u>Gravel Gravel</u> | | <u>121</u> | <u>137</u> | <u>16</u> |

8. WELL CONSTRUCTION
 Depth Drilled 137 Feet Depth Cased 138 Feet

HOLE DIAMETER (BIT SIZE)
 From 105/8 Inches 1 Feet 137 Feet
 To 137 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>65/8</u> | <u>13</u> | <u>1.88</u> | <u>1</u> | <u>137</u> |

Perforations:
 Type perforation Jet
 Size perforation 3/16 x 6 x 100
 From 127 feet to 136 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 137 feet

9. WATER LEVEL
 Static water level 45' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60 °F Quality Good

Date started 7/2/97, 19____
 Date completed 7/2/97, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------------|-------------------------------|--------------|
| <u>20-25</u> | <u>2 1/2</u> | <u>2 1/2</u> |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Peach Drilling Inc Contractor
 Address 20 599 Contractor
SS NV 84225

Nevada contractor's license number issued by the State Contractor's Board 0031841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876

Signed [Signature]
 Date 7/2/97

RECEIVED
 97 JUL -9 AM 11:19
 STATE ENGINEERS OFFICE