

OFFICE USE ONLY
 Log No. 67553
 Permit No. _____
 Basin 176

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33251

1. OWNER Wayne Cirone ADDRESS AT WELL LOCATION Lot #7 Block C
 MAILING ADDRESS 5775 Whitman St. Unit #1
Carson City, NV 89704
 2. LOCATION NE 1/4 SE 1/4 Sec. 9 T. 28 N/S R. 58 East Elko County
 PERMIT NO. 07-03A-16-4 Ruby Valley Estates
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown fine sand		0	15	15
Brown clay		15	25	10
Multi colored course sand		25	45	20
Black & white grav		45	70	25
Multi colored course sand		70	95	25
Brown clay with white & black course sand		95	130	35
Multi colored course sand	X	130	135	5
Brown clay		135	150	15
Black & white course sand		150	178	28
T.D. 178'				

8. WELL CONSTRUCTION
 Depth Drilled 178 Feet Depth Cased 178 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 1.78 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	.188	+1 1/2	178

Perforations:
 Type perforation Factory Sawn
 Size perforation 3/32 X 3
 From 158 feet to 178 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 178 feet to 50 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality Good

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		2 hours

Date started April 19 1997
 Date completed April 21 1997

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & Well Service, Inc.
 Contractor
 Address 1800 1/2 Frazer Ave
 Contractor
Sparks NV 89431
 Nevada contractor's license number issued by the State Contractor's Board 0035387-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date April 24, 1997