

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33250

1. OWNER Brad Keife ADDRESS AT WELL LOCATION Lot #3 Block C Unit #1
 MAILING ADDRESS 325 S. 18th St. Sparks, NV 89431

2. LOCATION NE 1/4 SW 1/4 Sec. 9 T 28 N/S R 58 East Elko County
 PERMIT NO. 07-03A-12-3 Ruby Valley Estates
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Brown Clay		2	6	4
Brown D.G.		6	12	6
Multi colored course gravel with some brown clay		12	120	108
Multi colored Course sand		120	135	15
Brown clay some multi colored gravel		135	155	20
Brown & white course sand	X	155	178	23
T.D. 178'				

8. WELL CONSTRUCTION
 Depth Drilled 178 Feet Depth Cased 178 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 178 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.92</u>	<u>.188</u>	<u>+2</u>	<u>178</u>

Perforations:
 Type perforation Factory Sawn
 Size perforation 1/8 X 3
 From 158 feet to 178 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 178 feet

9. WATER LEVEL
 Static water level 35 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & Well Service, Inc. Contractor
 Address 1800 1/2 Frazer Ave. Sparks, NV 89431 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0035387-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date April 24, 1997

Date started April 18, 1997
 Date completed April 19, 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30+</u>		<u>3 hours</u>