WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67556
Permit No.
Basin 176

NOTICE OF INTENT NO. 33255

1. OWNER Dennis McIntyre
MAILING ADDRESS 1430 Southview Dr.
Sparks, NV 89436

ADDRESS AT WELL LOCATION
Lot#2 Block F Unit#2

2. LOCATION SE ¼ SE ¼ Sec 9 T 28 N/S R 58 East Elko County
PERMIT NO. (Issued by Water Resources) 07-03A-33-9 (Parcel No.) Ruby Nalley Estates (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown fine sand		0	15	15
Multi colored gravel		15	25	10
multi colored course sand		25	70	45
multi colored gravel with brown clay		70	90	20
Multi colored gravel	X	90	120	30
T.D. 120'				

Date started May 22, 19 97
Date completed May 22, 19 97

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		2 Hrs.

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	120 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	.188	+1½	120'

Perforations:
Type perforation Factory Sawed
Size perforation 3/32 x 3
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 120 feet to 50 feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.S.A.P. Pump & Well Service, Inc. (Contractor)
Address 1800 ½ Frazer Ave. (Contractor)
Sparks, NV 89431
Nevada contractor's license number issued by the State Contractor's Board 35387-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
Signed Larry Wilch (By driller performing actual drilling on site or contractor)
Date May 27, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627