

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33257

1. OWNER Sheryle Pepper ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 6616 Delphinium Ave. Lot #5 Block C Unit #1  
Las Vegas, NV 89108

2. LOCATION NE 1/4 SE 1/4 Sec 9 T 28 Q/S R 58 east Elko County  
 PERMIT NO. 07-03A-14-9 Ruby Valley Estates  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Brown D.G.</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>Fine white sand</u>		<u>10</u>	<u>20</u>	<u>10</u>
<u>Multi colored gravel</u>		<u>20</u>	<u>60</u>	<u>40</u>
<u>Multi colored gravel with brown clay</u>	<u>X</u>	<u>60</u>	<u>120</u>	<u>60</u>
<u>T.D. 120'</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 120 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.92</u>	<u>.188</u>	<u>+1 1/2</u>	<u>120'</u>

Perforations:  
 Type perforation Factory Sawn  
 Size perforation 3/32 x 3  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 120 feet to 50 feet

9. WATER LEVEL  
 Static water level 35 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A.S.A.P. Pump & Well Service, Inc.  
Contractor  
 Address 1800 1/2 Frazer Ave.  
Contractor  
Sparks, NV 89431  
 Nevada contractor's license number issued by the State Contractor's Board 35387-A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066  
 Signed Jamy Welch  
by driller performing actual drilling on site or contractor  
 Date May 27, 1997

Date started May 21 1997  
 Date completed May 21 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>2 Hrs.</u>