

OFFICE USE ONLY  
 Log No. 675691  
 Permit No. \_\_\_\_\_  
 Basin. 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27865

1. OWNER Dave Ference ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS PO Box 5173 2616 ERIN CRT  
GARD. NV 89410 MINDEN NV 89423  
 2. LOCATION SW 1/4 NE 1/4 Sec 2 T 13 N/S R 20 E Douglas County  
 PERMIT NO. Parcel # 23-090-72 23-090-72 Johnson Lake Subdivision Name  
Issued by Water Resources Parcel No.

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE  
 New Well  Replace  Recondition  Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Deepen  Abandon  Other \_\_\_\_\_  Municipal/Industrial  Monitor  Stock  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil & Sand		0	10	
Light Sand & gravel		10	75	
Sand Clay & Gravel		75	135	
Sand & Clay		135	150	
Sand & gravel		150	175	
SANDY CLAY		175	180	
SAND & GRAVEL		180	210	
CLAY SAND & Gravel	X	210	215	
SAND	X	215	245	
CLAY & SAND	X	245	285	
CLAY SAND & Gravel	X	285	320	

8. WELL CONSTRUCTION  
 Depth Drilled 320 Feet Depth Cased 320 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 9 7/8 Inches To 320 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.5 lbs</u>	<u>.188</u>	<u>0</u>	<u>320</u>

Perforations:  
 Type perforation Factory Perf.  
 Size perforation 3" x 3 1/2" 32"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 300 feet to 280 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 320 feet to 50 feet

Date started 2-9 1997  
 Date completed 2-13 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>35+</u>	<u>—</u>	<u>3 hrs.</u>

9. WATER LEVEL  
 Static water level 205 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Kauchack Drilling Inc Contractor  
 Address PO Box 901 Minden NV 89423 Contractor  
 Nevada contractor's license number #021268 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the #1495 Division of Water Resources, the on-site driller.  
 Signed Michael Allen  
 By driller performing actual drilling on site or contractor  
 Date 2-13-97