

OFFICE USE ONLY
 Log No. 107638
 Permit No. _____
 Basin 137B
 NOTICE OF INTENT NO. 31365

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER RICHARD WOOD ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS HC 65 Box 16 85 GILLMAN CIRCLE
GILLMAN SPRINGS AUSTIN NEV 89310 GILLMAN SPRINGS AUSTIN NEV 89310
 2. LOCATION SW 1/4 NE 1/4 Sec 10 T. 16 N/S R. 44 E LANDER County
 PERMIT NO. _____ Parcel No. 04-031-05 Subdivision Name GILLMAN SPRINGS RANCH
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TAN CLY		0	15	15
GRAVEL		15	18	3
TAN CLY		18	24	6
SAND		24	27	3
BRN CLY		27	32	5
SMALL GRAVEL		32	36	4
BRN CLY		36	51	15
GRAVEL		51	54	3
BRN CLY		54	65	11
GRAVEL		65	67	2
BRN CLY		67	73	6
GRAVEL		73	76	3
BRN CLY		76	94	18
GRAVEL	Y	94	98	4
BRN CLY		98	110	12
GRAVEL	Y	110	116	6
BRN CLY		116	137	21
GRAVEL & CH STRAIN	Y	137	158	21
DANCLY		158	162	4
GRAVEL	Y	162	168	6
BRN CLY		168	170	2

8. WELL CONSTRUCTION
 Depth Drilled 170 Feet Depth Cased 170 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 50 Feet
8 3/4 Inches 50 Feet 170 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>72</u>	<u>170</u>

Perforations:
 Type perforation MILLED
 Size perforation 3 1/8
 From 140 feet to 170 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 5.0 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 22 feet below land surface
 Artesian flow NO G.P.M. 25 P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WOYTEL DRILLING CO. INC Contractor
 Address 2220 STONE DR. Contractor
RENO NEVADA 89511
 Nevada contractor's license number issued by the State Contractor's Board 084521A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
 Signed Thomas M. Hanks
 By driller performing actual drilling on site or contractor
 Date 4-29-97

Date started 4-28 1997
 Date completed 4-30 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>		<u>7</u>