

OFFICE USE ONLY
 Log No. 167642
 Permit No. _____
 Basin. 87

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33898

1. OWNER CITY OF RENO ADDRESS AT WELL LOCATION Southwest Corner, West First Street and North Sierra St.
 MAILING ADDRESS 490 South Center St., Ste. 203 Reno, NV 89505

2. LOCATION NW 1/4 SE 1/4 Sec. 11 T. 19 N/S R. 19 E (MDBM) Washoe County
 PERMIT NO. 11-111-07 Downtown Reno Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
FILL - Sand and Gravel		0	6'	6'
GRAVEL and sand with cobbles and boulders		6'	18'	12'
-first water at 18'				
GRAVEL and sand, and cobbles and boulders		18'	34.5'	16.5'

Consultant:
 ENVIRONMENTAL MANAGEMENT ASSOC.
 100 W. Grove St. Ste. 100
 Reno NV 89509-4026

8. WELL CONSTRUCTION
 Depth Drilled 34.5 Feet Depth Cased 34.5 Feet

HOLE DIAMETER (BIT SIZE)
 From 7.5 Inches To 0 Feet 34.5 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" PVC		sch 40	0	34.5

Perforations:
 Type perforation slot
 Size perforation 0.020 in.
 From 14.5 feet to 34.5 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 10' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Bentonite Seal: 10-12'
 Gravel Packed: Yes No
 From 12.0 feet to 34.5 feet

9. WATER LEVEL
 Static water level 16.45 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 59.5 °F Quality not known

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. Box 12370 Contractor
Reno, NV 89510
 Nevada contractor's license number issued by the State Contractor's Board 022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
 Signed [Signature] by driller performing actual drilling on site or contractor
 Date July 21, 1997

Date started June 3, 1997
 Date completed June 4, 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)