

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 28460

1. OWNER MS. BETTIE KANELOS ADDRESS AT WELL LOCATION 320 HANSEN LN.
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE, NV

2. LOCATION NW 1/4 SW 1/4 Sec 35 T 12 N R 19 E DOUGLAS County
 PERMIT NO. 19-070-26 FOOTHILL
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MWD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY TOPSOIL		0	1	1
CLAY w/DG		1	7	6
SANDY DG	✓	7	80	73
DG	✓	80	105	25
BROWN CLAY		105	110	5
COARSE DG	✓	110	150	40

RECEIVED
 MAY 21 11:33
 DIVISION OF WATER RESOURCES

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 150 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 150 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>150</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 1/8 x 3
 From 120 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 150 feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow 10+ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 879 RITTER DR Contractor
GARDNERVILLE, NV 89410
 Nevada contractor's license number issued by the State Contractor's Board 27673A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1533
 Signed Scott Chittam
 By driller performing actual drilling on site or contractor
 Date 5/19/97

Date started 5/13, 1997
 Date completed 5/19, 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>25+</u>	<u>—</u>	<u>1</u>