WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 676556
Permit No.
Basin 105

NOTICE OF INTENT NO. 36255

1. OWNER Dave Moline Const.
MAILING ADDRESS 1360 Elges Lane
Gardnerville NV 89410

ADDRESS AT WELL LOCATION Lot B-3 Currant Ct.

2. LOCATION NE ¼ NE ¼ Sec. 1 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. (Issued by Water Resources) 23-483-20 (Parcel No.) Wild Flower (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Red Clay & Rocks		0	8	8
Sand & Gravel		8	12	4
Red Clay		12	17	5
Sand & Gravel		17	29	12
Sandy Clay		29	129	100
Sand & Gravel		129	135	6
Dark Clay		135	149	14
Sand Gravel & Clay		149	216	67
Clay		216	230	81
Sand & Gravel	X	230	237	7
Clay		237	242	5
Sand & Gravel	X	242	252	10
Clay		252	260	8
Sand & Gravel	X	260	286	26
Clay		286	290	4

RECEIVED 97 AUG -8 PM 12:54 STATE ENGINEER'S OFFICE

Date started July 29, 1997
Date completed Aug 4, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	+25		2 hrs

8. WELL CONSTRUCTION
Depth Drilled 290 Feet Depth Cased 290 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	50 Feet
9 7/8 Inches	50 Feet	290 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+3	290

Perforations:
Type perforation 3/16 x 4 Factory Cut
Size perforation 3/16 x 4 6 Rd
From 250 feet to 290 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 290 feet

9. WATER LEVEL
Static water level 187 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eddco Exploration Inc (Contractor)
Address 7780 Curry Rd Fallon NV (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 27673A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Aug 4 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627