WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67681
Permit No.
Basin 087

NOTICE OF INTENT NO. 27457

1. OWNER Goodyear Auto Center Parklane Mall
MAILING ADDRESS 2310 So. Virginia Reno, Nv.
ADDRESS AT WELL LOCATION same

2. LOCATION B ¼ A ¼ Sec. 24 T. 19 N/S R. 19 E. Washoe County
PERMIT NO. Old M/O 1081 (Issued by Water Resources) APN 015-220-32 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG MW-2

Material	Water Strata	From	To	Thickness
On 4/3/97 I found the well to be in good condition. After removing the cover I then proceeded to drill out the 2" casing to 30'. I then pressure grouted the hole from 30' to the surface with neat cement.				

RECEIVED 97 JUL 17 AM 11:22 STATE ENGINEERS OFFICE

Date started 4/3, 1997
Date completed 4/3, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 30' Feet Depth Cased N/A Feet

HOLE DIAMETER (BIT SIZE)
8" Inches From 0' Feet To 30' Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	Sch 40	PVC	0'	30'

Perforations:
Type perforation Factory
Size perforation .020
From 10' feet to 30' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 30'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 23' feet below land surface
Artesian flow no G.P.M. N/A P.S.I.
Water temperature cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andresen Exploration Drilling (Contractor)
Address 1635 Belford Rd. (Contractor)
Reno, Nv. 89509
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature] By driller performing actual drilling on site or contractor
Date 4/28/97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627