


OFFICE USE ONLY
 Log No. 67685
 Permit No. _____
 Basin. 105


PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32028

1. OWNER Doug & Linda Reagan ADDRESS AT WELL LOCATION 1153 Jacobsons Ln. Gardnerville NV. 89410
 MAILING ADDRESS 1153 Jacobsons Ln. Gardnerville NV. 89410
 2. LOCATION NW 1/4 SE 10 T. 12 S. R. 21 E. Douglas County
 PERMIT NO. 35-380-06 Parcel No. _____ Subdivision Name Fish Springs
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Cobbles & Boulders</u>		<u>0</u>	<u>19</u>	<u>19</u>
<u>Brown Clay</u>		<u>19</u>	<u>87</u>	<u>68</u>
<u>White Chalky Clay</u>		<u>87</u>	<u>230</u>	<u>143</u>
<u>Hard Granite</u>		<u>230</u>	<u>240</u>	<u>10</u>
<u>Broken Granite</u>		<u>240</u>	<u>245</u>	<u>5</u>
<u>Lost Mud Circulation At 240'</u>				
<u>Hard Gray Granite</u>		<u>245</u>	<u>300</u>	<u>55</u>
<u>D&G Gravels Rusty Granite w/water</u>	<u>xxx</u>	<u>300</u>	<u>330</u>	<u>30</u>

8. WELL CONSTRUCTION
 Depth Drilled 330 Feet Depth Cased 330 Feet
 HOLE DIAMETER (BIT SIZE)
 From 1 1/4 Inches 0 Feet 245 Feet
 To 8 3/4 Inches 245 Feet 330 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>1.88</u>	<u>0</u>	<u>330</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3 x 3/32
 From _____ feet to _____ feet
 From 290 feet to 330 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 55
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 55 feet to 330 feet

9. WATER LEVEL
 Static water level 240 feet below land surface
 Artesian flow _____ G.P.M. 30 P.S.I.
 Water temperature Cold °F Quality Good

Date started 4-1 1997
 Date completed 4-4 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u>45</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling Contractor
 Address 20 Kit Kat DR Contractor
Carson City NV. 89701
 Nevada contractor's license number 41775 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael Black
 By driller performing actual drilling on site or contractor
 Date 4-4-97