

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 67689
 Permit No. _____
 Basin 106

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32426
4025 Tapaz Ranch Rd

1. OWNER Don Robinson ADDRESS AT WELL LOCATION Tapaz NV
 MAILING ADDRESS 4025 Tapaz Ranch Rd.
 2. LOCATION Sw 1/4 Sw 1/4 Sec. 11 T 10 S R 22 E Douglas County
 PERMIT NO. 37-170-48 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Consolidated Gravels obsidian form</u>		<u>0</u>	<u>87</u>	<u>87</u>
<u>Brown Solid Sandy Clay</u>		<u>87</u>	<u>160</u>	<u>73</u>
<u>Small Gravels</u>		<u>160</u>	<u>190</u>	<u>30</u>
<u>Hard Granite (Green) with Clay seams</u>		<u>190</u>	<u>240</u>	<u>50</u>
<u>Hard (Green Granite HARD Fractures</u>		<u>240</u>	<u>290</u>	<u>40</u>
<u>Fractured Granite Areas: small Rusty Sands.</u>		<u>290</u>	<u>320</u>	<u>30</u>
<u>GPM - 18-20</u>				
<u>Static Water 120'</u>				

8. WELL CONSTRUCTION
 Depth Drilled 320 Feet Depth Cased 320 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 320 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 9/8</u>	<u>13.03</u>	<u>1.58</u>	<u>0</u>	<u>320</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3 x 3/32
 From 260 feet to 280 feet
 From _____ feet to _____ feet
 From 280 feet to 300 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 320 feet

9. WATER LEVEL
 Static water level 120 feet below land surface
 Artesian flow _____ G.P.M. 18-20 P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling Contractor
 Address 20 K.T. KAT DR. Contractor
Carson City NV. 89706
 Nevada contractor's license number 41775
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1905
 Division of Water Resources, the on-site driller
 Signed Michael Edhak
 By driller performing actual drilling on site or contractor
 Date 8-18-97

Date started 8-15, 1997
 Date completed 8-18, 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>18-20</u>	<u>110</u>	<u>4 1/2 HRS.</u>