

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 326022

1. OWNER Red Sun's Sand Development ADDRESS AT WELL LOCATION 1732 Sunset St
 MAILING ADDRESS P.O. Box 2947 Gardnerville NV 89423
Minden NV 89423

2. LOCATION SW 1/4 SW 1/4 Sec. 35 T. 13 S R. 20 E Douglas County
 PERMIT NO. 23-560-05
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Course Gravels</u>		<u>0</u>	<u>27</u>	<u>27</u>
<u>Brown Clay</u>		<u>27</u>	<u>34</u>	<u>7</u>
<u>Course Obsidian Sands</u>		<u>34</u>	<u>68</u>	<u>54</u>
<u>Dry Brown Sands</u>		<u>68</u>	<u>110</u>	<u>42</u>
<u>Fine Sands/obsidian Sands</u>		<u>110</u>	<u>148</u>	<u>38</u>
<u>Solid Brown Clay zone</u>		<u>148</u>	<u>203</u>	<u>55</u>
<u>Course fractured Gravels (Hard)</u>	<u>XXX</u>	<u>203</u>	<u>220</u>	<u>17</u>

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 10 3/4 Inches
 From 10 3/4 Inches To 220 Feet
 From _____ Inches To _____ Feet
 From _____ Inches To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>180</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3 x 3/32
 From 200 feet to 220 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100 feet to 220 feet

9. WATER LEVEL
 Static water level 110 feet below land surface
 Artesian flow _____ G.P.M. 25 P.S.I.
 Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling Contractor
 Address 20 Kit Kat DR. Contractor
Carson City NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael Dalk
 By driller performing actual drilling on site or contractor
 Date 7-7-97

Date started 7-1, 1997
 Date completed 7-3, 1997

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>	<u>45</u>	<u>3 HRS</u>

RECEIVED
 97 JUL 17 PM 4:55
 STATE ENGINEERS OFFICE