

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35871

1. OWNER Ron Evans ADDRESS AT WELL LOCATION  
 MAILING ADDRESS 2995 Lewis Lane 200 Lewis lane, fallon, Nv 89406  
 Fallon, NV 89406

2. LOCATION NW 1/4 SE 1/4 Sec. 28 T 19N N/S R 28E E Churchill County  
 PERMIT NO. 35871 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Brown Clay		5	10	5
Brown Sand		10	14	4
Clay		14	22	8
Sand		22	33	11
Gray Clay		33	38	5
Gray sand		38	49	11
Gray Clay		49	54	5
Gray sand		54	63	9
Brown Clay		63	65	2
Brown sand		65	70	5
Gravel & sand	X	70	76	6

8. WELL CONSTRUCTION  
 Depth Drilled 76 Feet Depth Cased 76 Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
10 Inches 0 Feet 76 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	76

Perforations:  
 Type perforation Mill Cut  
 Size perforation 1/8

From 73 feet to 76 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No  
 From 50 feet to 76 feet

9. WATER LEVEL  
 Static water level 12.5 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality Unknown

Date started 5/15/97, 19\_\_\_\_  
 Date completed 5/15/97, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>		<u>1 hr.</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor  
 Address P.O. Box 1265 Contractor  
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed W. J. [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 5-28-97