

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 33921

1. OWNER ED & CHRIS TARTAGLIA  
 MAILING ADDRESS P.O. Box 3118  
Sparks, Nevada 89432  
 ADDRESS AT WELL LOCATION 1405 Argonaught Way  
Reno, Nevada 89506  
 2. LOCATION SE NW 1/4 SW 1/4 Sec 26 T. 22N N/S R. 19 E Washoe County  
 PERMIT NO. 079-440-37 Antelope Valley Red Rock Est. #277 part 4  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Brown clay with decomposed granite		1	6	5
Fine brown sand		6	10	4
Brown sandy clay		10	49	39
Rusty weathered granite		49	55	6
Weathered granite		55	91	36
White hard granite		91	170	79
Fracture (app 3 GPM)	X	170	171	1
White hard granite		171	204	33
Fracture, granite	X	204	246	42
White granite		246	250	4

8. WELL CONSTRUCTION  
 Depth Drilled 250 Feet Depth Cased 250 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
8 5/8 Inches 50 Feet 250 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	250

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 203 feet to 243 feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50 feet  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 250 feet

9. WATER LEVEL  
 Static water level 148 feet below land surface  
 Artesian flow G.P.M. 50+ P.S.I.  
 Water temperature cold °F Quality clear

Date started 6-10-97, 19.....  
 Date completed 6-12-97, 19.....

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50+</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number issued by the State Contractor's Board 0022549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date June 16, 1997