

67721
 OFFICE USE ONLY
 Log No. 67721
 Permit No. _____
 Basin. 91

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33906

Consultant: Shaw Engineering, Ltd. Owner: _____
 1. OWNER MAILING ADDRESS 430 Stoker Ave., Suite 207 ADDRESS AT WELL LOCATION P.O. Box 399
 Reno, Nevada 89503 Verdi, Nevada 89439-0399
 2. LOCATION NW 1/4 SE 1/4 Sec. 16 T. 19N N/S R. 18 E Washoe County
 PERMIT NO. 22079 WELL #1 038-430-04 Boomtown
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 (Municipal) Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Day I 7-16-97				
Static water level @66 ft. BGS				
Total depth @167 ft. BGS				
1. Attempt to pull 6 5/8" liner - unsuccessful.				
2. Perforate 6 5/8" casing from 160 ft. 0 ft. Slot size 1/4 x 2" x 4 holes around, 16 holes per foot.				
3. Install tremie pipe to 160 ft. Mix & pump 27 sacks neat cement. Fluid level @65 ft.				
Day II				
Static water level @66 ft. BGS				
Water level @105 ft. BGS				
1. Install tremie pipe to 100 ft.				
2. Mix & pump 15 sacks neat cement. Fluid level @54 ft. Let set 30 minutes.				
3. Mix & pump 15 sacks neat cement. Fluid level @38 ft. Let set 45 minutes.				
4. Mix & pump 15 sacks neat cement. Fluid level @11 ft. Let set 30 minutes				
5. Mix & pump 6 sacks neat cement. Fluid level Full over top.				
Day III 7-18-97				
Static water level @2 ft 10" from top of casing				
1. Mix & add 7 sack neat cement				

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased _____ Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O BOX 12370 Contractor
 RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board. 0022549
 Nevada driller's license number issued by the Division of Water Resources the on-site driller. 908
 Signed *[Signature]*
 Driller performing actual drilling on site or contractor
 Date July 29, 1997

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift
 G.P.M. Draw Down (Feet Below Static) Time (Hours)
 Materials used: 79 sacks Portland Cement Type I
 Equipment used: T660 Schramm Drill, Holt down-hole perforator, pressure pump.
 Location: 49 ft N of Casino Building
 141 ft. E of retaining wall by St.