** Nye Co. changed the APN# on this lot from 28-592-16 to 28-592-26

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67725
Permit No.
Basin 162

NOTICE OF INTENT NO. 16644

1. OWNER Wolfgang Lettow
MAILING ADDRESS P.O. Box 5951
Pahrump, NV 89041

ADDRESS AT WELL LOCATION
4481 W. Blanchard St.
Pahrump, NV 89048

2. LOCATION NW ¼ NE ¼ Sec. 26 T. 20S N/S R. 52 E. Nye County
PERMIT NO. (Issued by Water Resources) 28-592-26 ** (Parcel No.) Vegas Acres U2/L46 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Grey Clay		4	24	20
Brown Clay		24	50	26
Grey Clay		50	80	30
Clay w/gravel		80	84	4
Loose sand & rocks	X	84	92	8
Rocks & clay		92	98	6
Loose sand & rocks	X	98	100	2

SEP 15 1997

Date started August 21, 1997
Date completed August 23, 1997

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	-0-	15 min.

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	100 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	17#	.188	0	100

Perforations:
Type perforation Torch cut
Size perforation ½" wide, 8" long
From feet to feet
From 80 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 100 feet

9. WATER LEVEL
Static water level 56 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg Well Drilling (Contractor)
Address 1060 W. Basin Rd. (Contractor)
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 7484

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725

Signed Charles Nyberg (By driller performing actual drilling on site or contractor)

Date Sept. 9, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627