

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28464
1473 Willow Creek
GARDNERVILLE, NV 89410

1. OWNER HEARTHESIDE HOMES
 MAILING ADDRESS 1659 HOLD ROAD
MINDEN, NV 89423
 ADDRESS AT WELL LOCATION _____
 2. LOCATION NW 1/4 SW 1/4 Sec 35 T 13
R 20 E DOUGLAS County
 PERMIT NO. 23 540 13
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILT W AB		0	20	20
COBBLES				
SILTY CLAY W		20	80	60
MINOR SMALL GRAVELS				
COBBLES, SANDY BROWN CLAY W SOME GRAVELS		80	115	35
COBBLES, SAND & GRVL	X	115	140	25
BROWN CLAY W MINOR SAND		140	160	20
COBBLES, SAND & GRVL	X	160	180	20

97 SEP 2 11:28 AM
 STATE ENGINEERING CONTROL

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet
180 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13</u>	<u>.188</u>	<u>+2</u>	<u>180</u>

Perforations:
 Type perforation SAWCUT
 Size perforation 3X 3/32
 From _____ feet to _____ feet
 From 120 feet to 140 feet
 From 160 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 60 FT Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 60 feet to 180 feet

9. WATER LEVEL
 Static water level 35 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality ?

Date started 8/5, 1997
 Date completed 8/7, 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50+</u>	<u>---</u>	<u>3</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA DRILLING, INC Contractor
 Address 75 LEWERS CREEK RD
CARSON CITY, NEVADA 89704
 Nevada contractor's license number 13697A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
 Signed Joe Reisch
 By Driller performing actual drilling on site or contractor
 Date 8/26/97