WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67769
Permit No.
Basin 212

NOTICE OF INTENT NO. 15947

1. OWNER SECOR C/O SOUTHLAND CORP
MAILING ADDRESS 19033 W. VALLEY HIGHWAY KENT, WA 98032
ADDRESS AT WELL LOCATION 2910 S. MARYLAND PKWY LAS VEGAS, NV

2. LOCATION NW ¼ SW ¼ Sec. 11 T. 21 N(S) R. 61 E. CLARK County
PERMIT NO. Issued by Water Resources | 162-11-310-001 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE MW-3
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0	0.3	0.3
POORLY GRADED SAND		0.3	4	3.7
SILTY SAND		4	10	6
SILT		10	15	5
POORLY GRADED SAND		15	24	9

AUG 11 1997

Date started JUNE 10, 1997
Date completed JUNE 10, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 24 Feet Depth Cased 23 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	24 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	1.9	0.237	0	23

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 13 feet to 23 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-10'/10-12' BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 12 feet to 24 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMAS HIGH (CONVERSE CONS) Contractor
Address 731 Pilot Rd Ste H Contractor
LAS VEGAS, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 0034757
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869
Signed By driller performing actual drilling on site or contractor
Date 8/15/97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627