

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 67793
 Permit No. 01
 Basin 01

PRINT OR TYPE ONLY
 NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36077

1. OWNER Ether Westmoreland ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS PO Box 2550 3210 Ether way Lot F8
Winnemucca, NV 89446 Winnemucca, NV 89445

2. LOCATION NE 1/4 RE-SE 1/4 Sec. 24 T 35N N/S R 37 E Humboldt County
 PERMIT NO. 10-102-08 04-103-2 Westmoreland Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	2	2
Sand & gravel		2	30	28
Cobbles w/sand & gravel		30	175	145
<u>N 40.890466</u>				
<u>42.758967 NAD27</u>				
<u>Deepened under NOI 62709</u>				
RECEIVED 97 APR - 5 AM 11:18 DIVISION OF WATER RESOURCES				

8. WELL CONSTRUCTION
 Depth Drilled 164 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 7/8 Inches 0 Feet 164 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>160</u>

Perforations:
 Type perforation Single row mill slot
 Size perforation 1/8 X 3

From 140 feet 160 feet
 From _____ feet _____ feet
 From _____ feet _____ feet
 From _____ feet _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100 feet 164 feet

9. WATER LEVEL
 Static water level 123 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature cool °F Quality good

Date started 4/8/97 19____
 Date completed 4/8/97 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Bailer Draw Down (Feet Below Static)	Pump Time (Hours)	Air Lift
	<u>20</u>		<u>2</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc. Contractor
 Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2019
 Signed [Signature] By driller performing actual drilling on-site or contractor
 Date 5-3-97