

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 67807
 Permit No. _____
 Basin 183

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **38512**

1. OWNER BLM ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS HC 33 Box 33500 Pony Springs
Ely, NV 89301-9408
 2. LOCATION NE 1/4 NE 1/4 Sec. 6 T 5N N/S R 66E E Lincoln County
 PERMIT NO. 59208 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Light tan clay		0	18	18
Coarse gravel		18	19	1
Sandy clay		19	95	76
Red volcanic w/clay		95	100	5
Gravel layered in clay		100	135	35
Clay		135	140	5
Clay & volcanic gravel		140	175	35
Brown volcanic		175	190	15
Volcanic & clay		190	235	45
Sand layers in clay		235	350	115

8. WELL CONSTRUCTION
 Depth Drilled 360 Feet Depth Cased 350 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
17.5 Inches 0 Feet 360 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4		.250	0	360

Perforations:
 Type perforation Johnson Wire Wrap S.S.
 Size perforation .090
 From 135 feet to 145 feet
 From 230 feet to 250 feet
 From 320 feet to 330 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 360 feet

9. WATER LEVEL
 Static water level 80 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Good

Date started 8/4/97, 19____
 Date completed 9/10/97, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>60</u>		<u>8 hrs.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc. Contractor
 Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713
 Signed Jeri G. Tomp
 By driller performing actual drilling on-site or contractor
 Date 9-22-97