

OFFICE USE ONLY
 Log No. 67825
 Permit No. 49
 Basin 49

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32052

1. OWNER GENE & SARRIN H GUMMERSALL ADDRESS AT WELL LOCATION None
 MAILING ADDRESS UNK Georgia Ave APN 032-004-019

2. LOCATION SW 1/4 SW 1/4 Sec 7 T 34 N/S R 56 E ELKO County
 PERMIT NO. LOT 19 BLKD LAST CHANCE RANCH UNIT #3
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay & Gravel		0	4	4
Soft sandstone		4	39	35
Clay		39	49	10
Sandstone/claystone		49	120	71
White clay		120	140	20
Sandstone (soft) sand		140	150	10
Gray clay		150	170	20
Gray clay	1/2 gpm	170	230	60
Clay w/ streaks of sand	8 gpm	230	289	59
	7.0	289	makes 10 gpm at 200 ft.	

8. WELL CONSTRUCTION
 Depth Drilled 290 Feet Depth Cased 291'8" Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 50 Feet
 From 8 Inches To 290 Feet
 From _____ Inches To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.92</u>	<u>.188</u>	<u>+ 2</u>	<u>290</u>

Perforations:
 Type perforation Touch cut
 Size perforation
 From 190 feet to 210 feet
 From 230 feet to 280 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 290 feet

9. WATER LEVEL
 Static water level 165 feet below land surface
 Artesian flow No G.P.M. P.S.I.
 Water temperature cold °F Quality good

Date started 5 1997
 Date completed 5-27 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>10</u>	<u>35</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name MUTH DRILLING Co. Contractor
 Address 203 PINE ST. Contractor
ELKO, NV 89801
 Nevada contractor's license number issued by the State Contractor's Board 10819
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
 Signed James Y. Muth
 By driller performing actual drilling on site or contractor
 Date 5-27-97