WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67840
Permit No.
Basin 49

NOTICE OF INTENT NO. 36880

1. OWNER Pat Milligan
MAILING ADDRESS 1934 Sierra Drive
Elko, NV 89801

ADDRESS AT WELL LOCATION NE corner of Hwy. 225 and Canyon Drive

2. LOCATION NW ¼ NE ¼ Sec. 7 T. 34N N/S R. 55 E. Elko County
PERMIT NO. (Issued by Water Resources) 83-001-016 (Parcel No.) Crestview (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Siltstone & Boulders		3	60	57
Brown Siltstone	X	60	460	400
some gravel &				
boulders mix				

RECEIVED
97 SEP 22 AM 11:19
STATE ENGINEER'S OFFICE

Date started August 28, 19 97
Date completed Sept. 2, 19 97

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		6

8. WELL CONSTRUCTION
Depth Drilled 460 Feet Depth Cased 460 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10-5/8 Inches	0 Feet	460 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+1	460

Perforations:
Type perforation Mill Slot
Size perforation 3/16 x 3
From 440 feet to 460 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 460 feet

9. WATER LEVEL
Static water level 370 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling, Inc. (Contractor)
Address P. O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed Dave Hausch (By driller performing actual drilling on site or contractor)
Date 9-3-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627