WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67858
Permit No.
Basin 048

NOTICE OF INTENT NO. 35[redacted]

1. OWNER ROYCE HACKWORTH
MAILING ADDRESS 1031 DOTTA DR
ELKO, NV 89801

ADDRESS AT WELL LOCATION
NO. SIDE OF SHERMAN BETWEEN 8TH & 9TH ST.

2. LOCATION SW 1/4 SW 1/4 Sec. 15 T 32N N/S R 55E E ELKO County
PERMIT NO. (Issued by Water Resources) | Parcel No. 27-028-06 | Subdivision Name LUCKY NUGGET #1

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	3	3
GRAVEL & SAND		3	40	37
SILTSTONE		40	120	80
BROWN VOLCANICS		120	180	60
RED VOLCANICS		180	240	60
WHITE VOLCANICS	X	240	300	60

RECEIVED 97 APR 28 AM 11:21 STATE ENGINEER'S OFFICE

Date started 4/22/97 , 19__
Date completed 4/22/97 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		3

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	300	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	300

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 280 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 105 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature WARM °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed Dani Hawes (By driller performing actual drilling on-site or contractor)
Date 4-24-97