WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67893
Permit No.
Basin 176

NOTICE OF INTENT NO. 33256

1. OWNER William Harmon
MAILING ADDRESS 425 Wilson St. #2
Elko NV 89801

ADDRESS AT WELL LOCATION
Lot #1 Block C Unit #1

2. LOCATION NE ¼ SE ¼ Sec. 9 T 28 N/S R 58 E/W East Elko County
PERMIT NO. (Issued by Water Resources) 07-03A-10-7 (Parcel No.) Ruby Valley Estates (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown D.G.		0	15	15
Brown Sticky Clay		15	45	30
Multi colored grav		45	135	90
Brown Clay sticky		135	170	35
Multi colored grav		170	190	20
Multi colored grav with brown clay	X	190	240	50
T.D. 240'				

Date started May 22, 1997
Date completed May 24, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		2 Hrs.

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 5/8 Inches	0 Feet	240 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.9	.188	+1½	240

Perforations:
Type perforation Factory Sawed
Size perforation 3/32 x 3 Double rows
From 220 feet to 240 feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 240 feet to 100 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.S.A.P. Pump & Well Service, Inc. (Contractor)
Address 1800 ½ Frazer Ave. (Contractor)
Sparks, NV 89431
Nevada contractor's license number issued by the State Contractor's Board 35387-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
Signed Larry Welch (By driller performing actual drilling on site or contractor)
Date June 2, 1997

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627