WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67921
Permit No.
Basin 105

I

NOTICE OF INTENT NO. 32639

1. OWNER Gregg Lynn Construction
MAILING ADDRESS Andy & Carole Voage
ADDRESS AT WELL LOCATION 1525 Salt Brush ct. Gardnerville NV. 89423

2. LOCATION ~~NE~~ SE ¼ ~~SW~~ NW ¼ Sec. 36 T. ~~12~~ 13 N/S R. 20 E. Douglas County
PERMIT NO. (new gpn#1320-36-001-015) 23-472-26
Issued by Water Resources — Parcel No. — Subdivision Name: Wildflower Area

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay and Gravels		0	80	80
Brown Sandy Clay		80	220	140
Gummy Brown Clay (Solid)		220	310	90
Brown Clay Zone w/Zone of Gummy Clay		310	405	
Gray Clay Zone With Small Course Oblivial Sands	xx	405	440	35
	Gray Clay	435	440	5
ID 440'				

RECEIVED 97 JUL 25 AM 10:03 STATE ENGINEERS OFFICE

NEW APN# 1320-36-001-015

Date started 7-18, 1997
Date completed 7-22, 1997

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
~~[illegible]~~ 20	160	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 440 Feet Depth Cased 440 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11¼ Inches	0 Feet	440 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	440

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 420 feet to 440 feet
From 360 feet to 380 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 440 feet

9. WATER LEVEL
Static water level 195' feet below land surface
Artesian flow G.P.M. 20 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling (Contractor)
Address 20 Kit Kat DA (Contractor)
Carson City NV. 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack
By driller performing actual drilling on site or contractor
Date 7-23-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627