WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67922
Permit No.
Basin 1100

NOTICE OF INTENT NO. 5341

1. OWNER Hawthorne Army Depot
MAILING ADDRESS U.S. Hwy 95 Hawthorne Nev. 89415
ADDRESS AT WELL LOCATION Hawthorne Army Depot - Hawthorne Nevada 89415 Bldg # 70

2. LOCATION NW ¼ NW ¼ Sec. 14 T. 8 N/S R. 30 E. Mineral County
PERMIT NO. Water Grantee Issued by Water Resources
Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil - Backfill		0	20	20
Brn med - Fine sand		20	23	3
Dk grey/Black coarse to Fine Sand		23	31	8
Grey/green Fine Sand to Silt		31	46	15
Brn Med to Fine Sands		46	50	4
Green silty clay		50	52	2
Brn silty sand		52	53	1
Green/Brn sand & silt		53	69	17
Brn silty sand		69	80	11
Brn med to Fine sand		80	89	9
Soil Vapor Monitoring well Also water well				
Kimw 09				

Date started July 10, 1997
Date completed July 12, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NONE		

8. WELL CONSTRUCTION
Depth Drilled 89 Feet Depth Cased 88 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	Feet
8"	0	89

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1/4"	Polyethylene tubing		+1	14.5
1/4"	" "	" "	+1	31.0
1/4"	" "	" "	+1	37.5

Perforations:
Type perforation Slotted (1" x 6") Screen
Size perforation .010
From 14.5 feet to 15.0 feet
From 31.0 feet to 31.5 feet
From 37.5 feet to 38.0 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 11.5
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From (13.5 - 15.5) (30.5 feet to 32.5) (86.5 - 89.0) feet

9. WATER LEVEL
Static water level N/A feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ape Christensen Contractor
Address 11001 Etiwanda Ave Contractor
Fontana - Ca 92337
Nevada contractor's license number issued by the State Contractor's Board 0019101
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1468
Signed Steve Johnson By driller performing actual drilling on site or contractor
Date July 18 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627