WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67934
Permit No.
Basin 101

NOTICE OF INTENT NO. 36205

1. OWNER R. GETTO CONSTRUCTION
MAILING ADDRESS 1794 TUMBLEWEED ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION
2110 SILVER CIRCLE

2. LOCATION NW 1/4 SE 1/4 Sec. 35 T 19N N/S R 28E E CHURCHILL County
PERMIT NO. (Issued by Water Resources) Parcel No. 008-811-54 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	18	18
BROWN CLAY		18	22	4
BROWN SILT		22	40	18
BROWN CLAY		40	43	3
GREY SAND		43	63	20
BLACK SILT/CLAY		63	90	27
GREY SAND		90	102	12
BROWN CLAY		102	104	2
BROWN SAND	X	104	128	24

RECEIVED 97 APR 30 AM 10:19 STATE ENGINEER'S OFFICE

Date started 4/11/97, 19__
Date completed 4/11/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 128 Feet Depth Cased 128 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6 1/8	Inches	50	Feet	128	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	128

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 121 feet to 126 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured

Seal Type:
[X] Neat Cement/Bensal
[ ] Cement Grout
[ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 11.4 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Drilling Corp. (Contractor)
Address 305 E. WILLIAMS AVE. P. O. BOX 888 (Contractor)
FALLON, NV 89407

Nevada contractor's license number issued by the State Contractor's Board 11752

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996

Signed (By driller performing actual drilling on-site or contractor)

Date 4-29-97