



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 227942  
 Permit No.  
 Basin 105  
 NOTICE OF INTENT NO. 32631

1. OWNER Golden Valley Const. ADDRESS AT WELL LOCATION 1881 Milkweed Ct. Gardnerville Nv. 89423  
 MAILING ADDRESS P.O. Box 1765 Minden Nv. 89423  
 2. LOCATION SE 1/4 SE 1/4 Sec. 36 T. 13 S R. 20 E. Douglas County  
 PERMIT NO. 23-473-37 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Brown Clay and Sands</u>		<u>0</u>	<u>8</u>	<u>8</u>
<u>1/4 Gravels</u>		<u>8</u>	<u>73</u>	<u>65</u>
<u>Course Sands and Gravels</u>		<u>73</u>	<u>110</u>	<u>37</u>
<u>Brown Clay small Sandy Zones</u>		<u>110</u>	<u>265</u>	<u>155</u>
<u>Solid Brown Gummy Clay</u>		<u>265</u>	<u>340</u>	<u>75</u>
<u>Broken Fractures small Gravels</u>	<u>XX</u>	<u>340</u>	<u>375</u>	<u>35</u>

8. WELL CONSTRUCTION  
 Depth Drilled 375 Feet Depth Cased 375 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 3/4 Inches To 3 7/8 Feet  
 From 0 Feet To 375 Feet  
 From \_\_\_\_\_ Inches To \_\_\_\_\_ Feet  
 From \_\_\_\_\_ Inches To \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13.03</u>	<u>1.88</u>	<u>0</u>	<u>375</u>

Perforations:  
 Type perforation Mill Slot  
 Size perforation 3x 3/32  
 From 305 feet to 375 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 375 feet

9. WATER LEVEL  
 Static water level 165 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 30+ P.S.I.  
 Water temperature Cold °F Quality Good

Date started 5-22 1997  
 Date completed 5-29 1997

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30+</u>	<u>70</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Capital City Well Drilling Contractor  
 Address 20 Kot Kat DR. Carson City Nv. 89201 Contractor  
 Nevada contractor's license number 41775 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
 Signed Michael J. Baker  
 By driller performing actual drilling on site or contractor  
 Date 5-29-97