

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO: 36441

1. OWNER E.D. Goughard ADDRESS AT WELL LOCATION Black N Lot 17
 MAILING ADDRESS P.O. Box 585
Elko NV

2. LOCATION N 1/2 1/4 N 1/2 1/4 Sec 6 T. 34 S. R. 50 E. E1K0 County _____
 PERMIT NO. _____ LCR # 3
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	2	2
Caliche		2	6	4
Sand clay		6	12	6
Sand stone		12	43	31
Brown clay		43	62	19
Blue clay		62	430	368
Sand clay gravel	X	430	482	52
Clay		482	490	8

8. WELL CONSTRUCTION
 Depth Drilled 490 Feet Depth Cased 490 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 490 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188</u>	<u>0</u>	<u>490</u>

Perforations:
 Type perforation Fac
 Size perforation _____
 From 470 feet to 490 feet
 From 430 feet to 450 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 490 feet

9. WATER LEVEL
 Static water level: 104 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started August 5 1997
 Date completed August 8 1997

7. WELL TEST DATA

TEST METHOD: <input checked="" type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>207</u>	<u>66</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Steve Well Service Contractor
 Address P.O. Box 10 Contractor
Elko NV
 Nevada contractor's license number issued by the State Contractor's Board: 0038169
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1438
 Signed Shane Bennett
 By driller performing actual drilling on site or contractor
 Date August 8 - 97