

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

As # 72915  
 OFFICE USE ONLY 67970  
 Log No. ~~67970~~  
 Permit No. ~~070~~  
 Basin ~~070~~  
 NOTICE OF INTENT NO. 30423

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER Lon Armstrong ADDRESS AT WELL LOCATION Lot 6 - physical address pending  
 MAILING ADDRESS P.O. Box 2030  
WINNEMUCCA, NV 89446  
 2. LOCATION NW 1/4, NW 1/4 Sec. 17, T. 36, S. 38, E. Humboldt, County  
Lot 6 Jones subdivision  
 PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY / Big GRAVEL		0	10	10
CLAY / COARSE GRAVEL		10	30	20
CLAY / COARSE GRAVEL		30	60	30
CLAY / fine GRAVEL		60	100	40
CLAY / GRAVEL		100	160	60
THICK CLAY		160	170	10
CLAY / fine GRAVEL	XX	170	200	30

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12</u>	<u>1 8/8</u>	<u>1</u>	<u>200</u>

Perforations:  
 Type perforation Factory Cuts  
 Size perforation 3/32  
 From 170 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 68  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 68 feet to 200 feet

9. WATER LEVEL  
 Static water level 120 feet below land surface  
 Artesian flow NO G.P.M. N/A P.S.I.  
 Water temperature 60.1 °F Quality GOOD

Date started 3/22 1996  
 Date completed 3/25 1996

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>	<u>N/A</u>	<u>4 hr</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FRED ANDERSON Contractor  
 Address 10760 GRASS VALLEY  
WINNEMUCCA, NV 89445 Contractor  
 Nevada contractor's license number 21467  
 issued by the State Contractor's Board.  
 Nevada driller's license number 1375 issued by the  
 Division of Water Resources, the on-site driller.  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 5/12/96