WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67989
Permit No.
Basin 1C1

NOTICE OF INTENT NO. 30926

1. OWNER CHURCHILL CO. LOT
MAILING ADDRESS 7370 N. MAINE ST.
FALLON, NV.
ADDRESS AT WELL LOCATION SAME

2. LOCATION SW ¼ SW ¼ Sec. 30 T. 19 N/S R. 29 E. CHURCHILL County
PERMIT NO. CLD m/o 692 (Issued by Water Resources) 001-124-05 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG MW-10

Material	Water Strata	From	To	Thickness
ON 2/11/97, I				
FOUND THE WELL				
TO BE IN GOOD				
CONDITION. I				
THEN DRILLED				
THE CASING				
OUT TO 15'.				
I THEN PRESSURE				
GROUTED THE				
HOLE ~~from~~ WITH				
NEAT CEMENT				
FROM 15' TO				
THE SURFACE				

RECEIVED 97 JUL 17 AM 11:25 STATE ENGINEER'S OFFICE

Date started 2/11, 1997
Date completed 2/11, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 15' Feet Depth Cased 15' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10"	0'	15'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	SCH.40	PVC	0'	15'

Perforations:
Type perforation FACTORY
Size perforation .020
From 5' feet to 15' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 15'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 7' feet below land surface
Artesian flow NO G.P.M. N/A P.S.I.
Water temperature LOW °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ANDRESEN EXPLORATION DRILLING (Contractor)
Address 1635 BELFORD RD. (Contractor)
RENO, NV.
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4/28/97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627