WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67996
Permit No.
Basin 087

NOTICE OF INTENT NO. 27456

1. OWNER Winner's Corner Fac
MAILING ADDRESS 2191 Pyramid Way Sparks, NV
ADDRESS AT WELL LOCATION Same

2. LOCATION SE ¼ SE ¼ Sec. 32 T. 20 N/S R. 20 E. Washoe County
PERMIT NO. Old M/O 656-A,B APN 027-33406
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG MW-3

Material	Water Strata	From	To	Thickness
On 4/2/97 found the well to be in good condition. After removing the cover, I then proceeded to drill out the 4" casing to 29.5' I then pressure grouted the hole from 29.5' to the surface with neat cement.				

RECEIVED
97 JUL 17 AM 11:24
STATE ENGINEERS OFFICE

Date started 4/2, 1997
Date completed 4/2, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 29.5 Feet Depth Cased N/A Feet

HOLE DIAMETER (BIT SIZE)
10" Inches From 0' Feet To 29.5' Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	Sch 40	PVC	0'	29.5'

Perforations:
Type perforation Factory
Size perforation .020
From 14.5 feet to 29.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 29.5
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 15' feet below land surface
Artesian flow No G.P.M. N/A P.S.I.
Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andresen Exploration Drilling Contractor
Address 1635 Belford rd. Contractor
Reno, NV 89509
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature]
By driller performing actual drilling on site or contractor
Date 4/28/97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627