WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68046
Permit No.
Basin 049

NOTICE OF INTENT NO. 30315

1. OWNER Dave Armuth
MAILING ADDRESS 161-9 Kittridge
Elko, NV 89801

ADDRESS AT WELL LOCATION SW Corner of E. 6th St. and Modoc Ave.

2. LOCATION SW ¼ SE ¼ Sec. 35 T. 35 N/S R. 55 E. Elko County
PERMIT NO. (Issued by Water Resources) 37-063-01 (Parcel No.) MVR #% (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☑ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown siltstone & gravel mix	X	160	260	100
Existing well 160 deep with 6 5/8 OD .188 wall casing				

Date started 6-11, 1996
Date completed 6-11, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60		3

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 248 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 1/8 Inches	160 Feet	260 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5		.250	140	248

Perforations:
Type perforation Torch Cut
Size perforation 3 row
From feet to feet
From 148 feet to 248 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal NA
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 90' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1689
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6-19-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68094
Permit No.
Basin 049

NOTICE OF INTENT NO. 30355

1. OWNER SAM & LILLY GARCIA
MAILING ADDRESS 1370 SAGECREST DR
ELKO, NV 89801

ADDRESS AT WELL LOCATION SO. SIDE OF 6TH ST. BETWEEN POWHATAN & MODOC AVE

2. LOCATION SW 1/4 SE 1/4 Sec. 35 T 35N N/S R 55E E ELKO County
PERMIT NO. (Issued by Water Resources) 37-063-03 (Parcel No.) MVR #5 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	2	2
BOULDERS & SOIL		2	8	6
SILTSTONE & BOULDERS		8	60	52
SILTSTONE		60	140	80
SILTSTONE & GRAVEL	X	140	260	120

RECEIVED
96 SEP -3 PM 2:18
STATE ENGINEERS OFFICE

Date started 8/23/96, 19__
Date completed 8/23/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		3

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8	Inches	0 Feet	260 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	260

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 240 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 260 feet

9. WATER LEVEL
Static water level 180 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 8-30-96