

OFFICE USE ONLY
 Log No. 68052
 Permit No. _____
 Basin. 049

I

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30580

1. OWNER Jennifer Conk ADDRESS AT WELL LOCATION So. Side of 6th
 MAILING ADDRESS 374-16 Kittridge Canyon between Seminole & Powhatan
Elko, NV 89801

2. LOCATION SE 1/4 SW 1/4 Sec. 35 T. 35 N 55 E Elko County
 PERMIT NO. 37-062-10-6 MVR #5
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	3	3
Rocks & Gravel		3	65	62
Rock		65	180	115
Silt Stone		180	265	85
Gravel	X	265	300	35

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10-5/8 Inches 0 Feet 300 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6-5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>300</u>

Perforations:
 Type perforation Millslot
 Size perforation 3/16 x 3 x 6 row
 From 280 feet to 300 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 300 feet

9. WATER LEVEL
 Static water level 190 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started 4-10, 1996
 Date completed 4-11, 1996

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Blow Test</u>	<u>35</u>		<u>4</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling Inc. Contractor
 Address P.O. Box 850 Contractor
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1995

Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 4-12-96