WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 28062
Permit No.
Basin 049

NOTICE OF INTENT NO. 31143

1. OWNER Olga Berroyer
MAILING ADDRESS 6658 Ishi Drive
Magalia, CA 95954

ADDRESS AT WELL LOCATION
NE Corner of 4th Street and Navajo

2. LOCATION NW ¼ NW ¼ Sec. 1 T 35 N/S R 56 E Elko County
PERMIT NO. Issued by Water Resources | 30-021-05-9 Parcel No. | MVR #1 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Topsoil		0	6	6'
Sand & Fine Gravel		6	34	28'
Brown Clay		34	45	11'
Sand	X	45	60	15'
Sand & Clay Layers		60	80	20'
Sand & Pea Gravel	X	80	120	40'

Date started 3-15, 19 96
Date completed 3-15, 19 96

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blow Test	60		2-1/2

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10-5/8 Inches		0 Feet	50 Feet
9-7/8 Inches		50 Feet	120 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13	.188	+1-1/2	120

Perforations:
Type perforation Mill Slot
Size perforation 3/16 x 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 120 feet

9. WATER LEVEL
Static water level 28 feet below land surface
Artesian flow -- G.P.M. -- P.S.I.
Water temperature Cold °F Quality --

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3-20-96

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627