

OFFICE USE ONLY  
 Log No. 108070  
 Permit No. \_\_\_\_\_  
 Basin. \_\_\_\_\_

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30413

1. OWNER Bob Cashell ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 704 3300 LARKSPUR  
WINNEMUCCA, NV 89446 WINNEMUCCA, NV  
 2. LOCATION SW 1/4 SW 1/4 Sec. 13 T. 35 S. R. 37 E. HUMBOLDT County  
 PERMIT NO. 13-581-13 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SAND</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>LARGE GRAVEL PIT</u>				
<u>ROCKS/SAND/GRAVEL</u>				
<u>LESS THAN 10% CLAY</u>		<u>96</u>	<u>150</u>	<u>145</u>

8. WELL CONSTRUCTION  
 Depth Drilled 150 Feet Depth Cased 150 Feet  
 HOLE DIAMETER (BIT SIZE)  
10 5/8 Inches From 1 Feet To 150 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>12</u>	<u>1.88</u>	<u>1</u>	<u>150</u>

Perforations:  
 Type perforation Factory Cuts  
 Size perforation 3/32  
 From 130 feet to 150 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 54  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 54 feet to 150 feet

9. WATER LEVEL  
 Static water level 9.7 feet below land surface  
 Artesian flow NO G.P.M. N/A P.S.I.  
 Water temperature COOL °F Quality GOOD

Date started 2/14, 1996  
 Date completed 2/17, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>N/A</u>	<u>2 hr</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FRED ANDERSON Contractor  
 Address 10760 GRASS VALLEY Contractor  
WINNEMUCCA, NV  
 Nevada contractor's license number 21467  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 1375  
 Division of Water Resources, the on-site driller.  
 Signed \_\_\_\_\_  
 Date 2/20/96