WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. L8071
Permit No.
Basin 071

NOTICE OF INTENT NO 32899

1. OWNER Walt Johnstone
MAILING ADDRESS 1394 Pronto Ave.
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 3745 Sego Rd.
Winnemucca, NV 89445

2. LOCATION NE ¼ SE ¼ Sec. 13 T. 35 N/S R. 37 E. Humboldt County
PERMIT NO. Issued by Water Resources | Parcel No. 13-581-07 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Cobbles w/gravel | | 0 | 85 | 85 |
| Boulders | | 85 | 155 | 70 |
| Fractured granite | | 155 | 204 | 49 |

Date started 7/30, 19 96
Date completed 7/31, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | | 2 |

8. WELL CONSTRUCTION
Depth Drilled 204 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 10 | 0 | 204 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .188 | +1 | 200 |
| | | | | |

Perforations:
Type perforation Single row mill slot
Size perforation 3 X 1/8
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 204 feet

9. WATER LEVEL
Static water level 154 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co. Inc. (Contractor)
Address 4675 W. Winnemucca Blvd. (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2019
Signed (By driller performing actual drilling on site or contractor)
Date 8/7/96

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627