WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68076
Permit No.
Basin 071

NOTICE OF INTENT NO. 35024

1. OWNER Kim Peterson
MAILING ADDRESS P.O. Box 1265
Winnemucca, NV 89446

ADDRESS AT WELL LOCATION
7075 Lazy P Court

2. LOCATION SW 1/4 SW 1/4 Sec. 1 T 36N N/S R 38E E Humboldt County
PERMIT NO. _____ Issued by Water Resources | County has not assigned Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	8	8
Gravel & cobbles		8	41	33
Clay		41	68	27
See next line	x	68	118	50
Clay w/gravel & cobble layers				
Clay		118		

Date started 6/18/97, 19__
Date completed 6/18/97, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		2 hrs.

8. WELL CONSTRUCTION

Depth Drilled 118 Feet Depth Cased 115 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	118 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	115

Perforations:
Type perforation Single row mill slot
Size perforation 1/8 x 3
From 95 feet to 115 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 115 feet

9. WATER LEVEL

Static water level 60 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc.
Contractor

Address 4675 W. Winnemucca Blvd
Contractor

Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562

Signed [signature]
By driller performing actual drilling on-site or contractor

Date 6-25-97