WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No 68077
Permit No.
Basin 071

NOTICE OF INTENT NO. 36192

1. OWNER Rick Grant
MAILING ADDRESS Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 6040 Water Cyn. Rd. Lot 7

2. LOCATION SW 1/4 SE 1/4 Sec. 33 T 36N N/S R 38E E Humboldt County
PERMIT NO. _____ Issued by Water Resources | Parcel No. 16-463-07 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cobbles & boulders		0	143	143
See next line		143	152	9
Small clay layers rock ledge				
Cobbles/boulders/clay		152	195	43
Fractured rock w/clay		195	240	45
Clay w/cobbles & gravel		240	310	70
Fractured rock w/clay		310	348	38
See next line		348	395	47
Fractured rock, sand & gravel some clay				

97 JUN 26 AM 10:29 STATE ENGINEER'S OFFICE

Date started 5/27/97, 19__
Date completed 6/2/97, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		8 hrs.

8. WELL CONSTRUCTION
Depth Drilled 395 Feet Depth Cased 388 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches		0 Feet	388 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	+2	390

Perforations:
Type perforation Mill slot
Size perforation 1/8
From 348 feet to 388 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 395 feet to 50 feet

9. WATER LEVEL
Static water level 276 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc.
Contractor
Address 4675 W. Winnemucca Blvd
Contractor
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562

Signed [signature]
By driller performing actual drilling on-site or contractor

Date 6-25-97