

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 68087
 Permit No. _____
 Basin 162

NOTICE OF INTENT NO. 15339

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Serenity Homes ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
Andy Jordan 881 W. Amarillo St
Pahrump, NV 89041
 2. LOCATION NW 1/4 SW 1/4 Sec 28 T. 20 N. R. 53 E. E. Nye County
 PERMIT NO. 40.202.09 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Blown Clay</u>		<u>0</u>	<u>6</u>	<u>6</u>
<u>Grey Clay</u>		<u>6</u>	<u>22</u>	<u>16</u>
<u>Dec. Caliche</u>		<u>22</u>	<u>30</u>	<u>8</u>
<u>Grey Clay</u>	<u>X</u>	<u>30</u>	<u>95</u>	<u>65</u>
<u>Caliche</u>	<u>X</u>	<u>95</u>	<u>98</u>	<u>3</u>
<u>Grey Clay</u>	<u>X</u>	<u>98</u>	<u>140</u>	<u>42</u>

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>		<u>Sch. 80 PVC</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation SAW
 Size perforation 3/16 x 5

From _____ feet to _____ feet
 From 110 feet to 130 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 54 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 8-8-97
 Date completed 8-12-97

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>2</u>	<u>1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Larry Water Well Service Contractor
 Address P.O. Box 3392 Contractor
Pahrump, NV 89041

Nevada contractor's license number issued by the State Contractor's Board: 0035901

Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1916

Signed Larry Jenkins
 By driller performing actual drilling on site or contractor

Date _____