


OFFICE USE ONLY
 Log No. 168089
 Permit No. _____
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15341

1. OWNER Serenity Homes ADDRESS AT WELL LOCATION CAVENDISH ST. RAHWAMP, NV 89041
 MAILING ADDRESS Andy Jenkins
 2. LOCATION NW 1/4 NE 1/4 Sec. 35 T. 20S N/S R. 53E E Nye County
 PERMIT NO. 42-701-11 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Soil	0	7		7
Broken clay	7	30		23
Grey clay	30	59		29
Broken clay	59	70		11
Caliche at	70	72		2
Grey clay	72	140		68

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet
140 Feet
 From _____ Inches _____ Feet _____ Feet
 From _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>		<u>Sch 80 PVC</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory
 Size perforation 3/16 x 5
 From _____ feet to _____ feet
 From 110 feet to 130 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level: 52 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

Date started 8-18 19 97
 Date completed 8-23 19 97

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>30</u>	<u>9</u>	<u>1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Larry Water Well Service Contractor
 Address P.O. Box 3592 Contractor
Rahwamp, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 0035901
 Nevada driller's license number issued by the Division of Water Resources the on-site driller: 1916
 Signed Larry Jenkins
 By driller performing actual drilling on site or contractor
 Date _____