

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 68090
Permit No. 212
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16495

1. OWNER St. Gabriel Church ADDRESS AT WELL LOCATION 2250 E. Maule Ave.
MAILING ADDRESS Same Las Vegas, Nev. 89119
2. LOCATION SE 1/4 NE 1/4 Sec. 2 T. 22 N. R. 61 E. Clark County
PERMIT NO. 42632 177-02-603-032 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
*(A) Remove pump		from well		
*(B) Cemented in		65Ft.		
according to original log				
*(C) Casing		XXXXXX	XXXXXX	XXXXXX
to dertigerated to pull <u>OK</u>				
to perforate.				
(D) 25 Sack neat cement		per yard		
(E) Poured from bottom up		2" Tremie pipe		

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)
From 0 Inches To 0 Feet
Inches Feet
Inches Feet
Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.156	+1	128
6 5/8			114	400

Perforations:
Type perforation
Size perforation
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal _____ Cement Grout
Placement Method: Pumped Poured Concrete Grout
Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

Date started 9/22/97, 19_____
Date completed 9/23/97, 19_____

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick Contractor
Address 5360 Bonita Vista Contractor
Las Vegas, Nev. 89129
Nevada contractor's license number 10062
issued by the State Contractor's Board.
Nevada driller's license number issued by the 552
Division of Water Resources, the on-site driller.
Signed V. H. Dimick
By driller performing actual drilling on site or contractor
Date 9-23-97